CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE



LISTING No. 3774-0923:0102 Page 1 of 1

CATEGORY: 3774 -- ELECTRIC LOCKS

LISTEE: SECURITRON MAGNALOCK550 Vista Blvd, Sparks, NV 89434

Contact: Erik Strauss (775) 355-5625 Fax (775) 355-5638

Email: eriks@securitron.com

DESIGN: Models EXD-1 and EXD-1F exit delay systems. Unit consists of the following

subassemblies: BPS-12, -1, -3, -4.5, -6, -9, -15, BPS-24, -1, -2, -3, -4, -6, -10, BPSM-12, -6,

-9, -15, BPSM-24-4, -6, or -10 Class 2 Output Power Supplies; MK or MKN Mortise Keyswitch; TSB-1, TSB-3, TSB-3B, 3100, 3300, 3600, 3700, LMS-1, LML-1, -2, TSH-BK, -CL, MXD-32, -62 exit device, TDM, TDMT, XDT logic timers and Series 32, 34, 38, 62, 68, 82, and SAM Series Locking Devices, and LCP Lock Control Panel. Refer to listee's data

sheet for detailed product description and operational considerations.

RATING: Input: 120VAC, Output: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as electric special egress-control device. Model EXD-1 is intended for installation on

non-fire rated doors. Model EXD-1F is intended for installation on wood or metal fire rated

doors. Authority having jurisdiction shall be consulted prior to installation.

NOTE: Both models may be used in conjunction with a separately listed fire alarm control panel,

however, the units must be connected via the panels dry relay contacts designated as "Auxiliary". Connection to the fire alarm control unit "trouble" or "alarm relay" contacts is

NOT approved.

Updated 08-05-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2010 Listing Expires June 30, 2011

Authorized By: FRANCIS MATEO, Program Coordinator

Fire Engineering Division